



CERTIFICATE

We are pleased to confirm that the supply and installation of maintenance free earthing of Akaaltech make earthing have been completed at our project site in Tughlakabad and the same are in service.

The resistance of the said earth pits was measured simultaneously and the values were found to be between 0.8 Ohms to 0.3 Ohms.

In view of the above we certify that the performances of the said earth pits are satisfactory.




(Abhishek Ranjan)
Maj
GE (AF) TKD